

# PRESSURE TEST CERTIFICATE

Site details	
Site name	Date
Address	Reference
	Technician
	Floor level
	Pipe reference
	Manifold reference

Please tick the appropriate boxes					
<input type="checkbox"/> Installation	<input type="checkbox"/> Re-pressurise	<input type="checkbox"/> Repair			
Test method	Hydraulic (Water)	<input type="checkbox"/>	Period of test	Min 30 mins	<input type="checkbox"/>
Test method	Co <sup>2</sup> (air)	<input type="checkbox"/>	Test pressure	Min 4 bar	<input type="checkbox"/>
Sufficient room to attach pumpset (minimum 250mm required)				<input type="checkbox"/> Yes	<input type="checkbox"/> N/A
Has the manifold label been fitted?					<input type="checkbox"/>

Ambiente recommends taking extra care when pressure testing in cold or sub-zero temperatures and would strongly advise against leaving any plain water in the system that may be at risk of freezing.

Description	Yes	No	Comments
System left drained	<input type="checkbox"/>	<input type="checkbox"/>	
System left full of water	<input type="checkbox"/>	<input type="checkbox"/>	
System left under pressure	<input type="checkbox"/>	<input type="checkbox"/>	

Signature of tester	Print name	Date

Signature of witness	Print name	Date